

Property	Test Method	Unit	Value
Density @ 15DC	D-1298	KG/M3	MAX 970
Kinomatic Viscosity @ 50 DC	D-445	CST	MAX 280
Visco.Rodwood1@37.7DC	Calculated	SECS	MAX 2500
Pour Point	D-97	DC	MAX 24
Flash Point	D-93	DC	MIN 65
Sulpfur Total	D-1552	WT%	MAX 3.5
Carbon residue(Conradson)	D-189	WT%	MAX 15
Ash	D-482	WT%	MAX 0.05
Water & Sediment	D-1796	VOL%	MAX 0.5
Calorific Value (Higher)	Calculated	MJ/KG	MIN 41.8