

| Property                    | Test Method | Unit  | Value    |
|-----------------------------|-------------|-------|----------|
| Density @ 15DC              | D-1298      | KG/M3 | MAX 990  |
| Kinomatic Viscosity @ 50 DC | D-445       | CST   | MAX 380  |
| Pour Point                  | D-97        | DC    | MAX 32   |
| Flash Point                 | D-93        | DC    | MIN 65   |
| Sulphur Total               | D-1552      | WT%   | MAX 3.5  |
| Carbon Residue ( Conradson) | D-189       | WT%   | MAX 15   |
| Ash                         | D-482       | WT%   | MAX 0.15 |
| Water & Sediment            | D-1796      | VOL%  | MAX 1.0  |
| Calorific Value ( Higher)   | Calculated  | MJ/KG | MIN 41.7 |